

EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Certificate no.:
MEDB0000BS2
Revision no.:
0

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED). This Certificate is issued by DNV SE based on the notification of the Federal Maritime and Hydrographic Agency of Germany.

This is to certify:

that the **Surface materials and floor coverings with low flame-spread characteristics: - adhesives used in the construction of 'A', 'B' & 'C' class divisions**

with type designation(s)
Sikaflex®-696

issued to

Sika Services AG
Zürich, Switzerland

is found to comply with the Implementing Regulation **(EU) 2025/1533** for

Item no. **MED/3.18e** (Row 1 of 1)

according to the following requirements:

IMO Res. MSC.36(63)-(1994 HSC Code) 7, IMO Res. MSC.97(73)-(2000 HSC Code) 7, IMO MSC/Circ.1120, SOLAS 74 Reg. II-2/3, SOLAS 74 Reg. II-2/5, SOLAS 74 Reg. II-2/9, SOLAS 74 Reg. X/3


Further details of the equipment and conditions for certification are given overleaf.

Date of issue: **2025-11-19**

Expiry date: **2030-11-18**

DNV local unit:
Augsburg

Approval Engineer:
Timo Linn



Notified Body
no.: **0098**



for **DNV SE**

Digitally Signed By:
Christine Mydlak-Röder

Christine Mydlak-Röder
Head of Notified Body

The mark of conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-surveillance module (D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Directive 2014/90/EU.

This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV SE of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled.

Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to USD 300 000.

Product description

"Sikaflex®-696" is an elastic 1-component polyurethane adhesive which cures on exposure to atmospheric moisture.

Application: 200 g/m²
Density : 1.3Kg/l

For further details see Type Examination documentation below.

Application/Limitation

Approved for use as adhesive with low flame spread characteristics, not generating excessive quantities of smoke nor toxic products in fire.

Maximum gross calorific value shall be documented separately where applicable (SOLAS Reg. II-2/5.3.2).

Approved for all colour variations.

Each product is to be supplied with its manual for installation and use.

Type Examination documentation

Document No.	Rev.	Title
SL_Z- 853_FTP2_Sikaflex -696_2025		Test report no. SL/Z-853/FTP2/0860a/2025 dated 22 August 2025 from SYCHTA LABORATORIUM Sp. J., Poland
SL_Z- 853_FTP5_Sikaflex -696_2025		Test report no. SL/Z-853/FTP5/0961a/2025 dated 22 August 2025 from SYCHTA LABORATORIUM Sp. J., Poland

Tests carried out

Tested according to IMO 2010 FTP Code Part 5 and Part 2.

Marking of product

The product or packing is to be marked with name and address of manufacturer, type designation, MED Mark of Conformity.